



**Chief Safety Officer Decision (Regulatory Equivalence)**

**Date:** 05 January 2016

**C-NLOPB Reference:** 2014-RQ-0100

**Applicant:** Husky Oil Operations Limited

**Applicant Reference:** RQF-WHP-0233

**Installation Name:** Husky Wellhead Platform

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Regulation:** *Subsection 17(9) of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer accepts the Applicant's, the operator of the Husky Wellhead Platform, use of *American Petroleum Institute (API) 521 – Pressure-relieving and Depressuring Systems* for determining thermal radiation limits for gas release systems in lieu of those indicated in Subsection 17(9) of the Installations regulations.

  
\_\_\_\_\_  
Chief Safety Officer