



Chief Safety Officer Decision (Regulatory Equivalence)

Date: 08 December 2015

C-NLOPB Reference: 2015-RQ-0048

Applicant: ExxonMobil Canada Ltd., as managing partner of ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-069

Installation Name: Hebron Installation

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Section 24 of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer accepts the use of a fire hose reel with a 25m hose length on the UPM Cellar deck mezzanine level of the Hebron Installation that will meet the requirements of the "National Fire Protection Association, NFPA 14 Standard for the Installation of Standpipe and Hose systems" in lieu of a fire hydrant as required in the Installations Regulations.


Chief Safety Officer