



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 30 Aug 2016

C-NLOPB Reference: 2015-RQ-0181

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-067-02 Rev 2

Installation Name: Hebron Installation


Authority: *Canada-Newfoundland and Labrador Atlantic Accord
Implementation Act, subsection 151(1) & section 205.069*

*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Newfoundland and Labrador Act,
subsection 146(1) and section 201.66*

Regulation: *Subparagraph 11(2)(b) of the Newfoundland Offshore
Petroleum Installations Regulations*

Decision:

The Chief Safety Officer accepts the Applicant's, the owner of the Hebron Installation, use of alternative means, for the Water in Oil analyzer and HVAC Damper cables, by installing the cables in temperature controlled environments and by adding mechanical protection against direct impact, in lieu of the requirements in Section 11(2)(b) of the *Newfoundland Offshore Petroleum Installations Regulations* which specify the use of *CSA 22.2 No 0.3 Test Methods for Electrical Wires and Cables* for Cold Bend and Impact testing of electrical wiring.



Chief Safety Officer