



Chief Safety Officer Decision (Regulatory Equivalence)

Date: 04 May 2016

C-NLOPB Reference: 2016-RQ-0095

Applicant: Transocean Canada Drilling Services Ltd.

Applicant Reference: RQF 249


Installation Name: MODU Henry Goodrich

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Subsections 27(1) and (3) of the Newfoundland Offshore Petroleum Installation Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the owner of the *MODU Henry Goodrich*, to have water supplied to the accommodation sprinkler system from a fresh water tank and the fire water main in accordance with the requirements of SOLAS, DNV-OS-D301 Fire Protection and the *National Fire Protection Association (NFPA) 13 – Standard for the Installation of Sprinkler Systems* in lieu of the requirement in the *Newfoundland Offshore Petroleum Installation Regulations* to have water supply provided from two dedicated sprinkler pumps.


Chief Safety Officer