

<u>Chief Safety Officer Decision</u> (Application for Substitution, Equivalency, or Exemption)

Date: 2 Ochser 7018

C-NLOPB Reference: 2017-RQ-0139

Applicant: Husky Energy

Applicant Reference: RQ-16-00000338

Installation Name: West White Rose Project

Authority: Canada-Newfoundland and Labrador Atlantic Accord

Implementation Act, subsection 151(1) & section 205.069

Canada-Newfoundland and Labrador Atlantic Accord

Implementation Newfoundland and Labrador Act, subsection

146(1) and section 201.66

Regulation: Section 27(1),(2) of the Newfoundland Offshore Petroleum

Installation Regulations

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the West White Rose Project, to install an automatic wet-pipe sprinkler system to cover the accommodations areas fed from two independent connections to the firewater main without the need for dedicated sprinkler pumps. This alternate arrangement provides an equivalent level of safety and is consistent with the National Fire Protection Association (NFPA) 13 - Standard for the Installation of Sprinkler Systems as referenced in the regulations.

This Decision is effective from the date of issuance herein until the earlier of:

- a) the date a Regulation referenced herein is repealed or the date a particular subsection that is the object of a substitution or exemption being granted hereby is amended or replaced, or
- b) the date on which the CSO and /or CCO (as applicable) revokes this Decision as a result of i) any enforcement action by the Board related to this Decision or ii) new information or analysis coming to light challenging the assessment upon which this Decision was based, including but not limited to any changes to commitments made by the Applicant in its application.

For greater certainty, Chief Safety Officer will no longer have authority under the Accord Acts to grant exemptions for Part III.1 transitional regulations once they are repealed.

Chief Safety Officer