



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: MAY 5, 2017

C-NLOPB Reference: 2017-RQ-0048

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-068

Installation Name: Hebron Installation

Authority: *Canada-Newfoundland and Labrador Atlantic Accord
Implementation Act, Subsection 151(1) & Section 205.069*

*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Newfoundland and Labrador Act, Subsection
146(1) and Section 201.66*

Regulation: *Newfoundland Offshore Petroleum Installations Regulations,
Subsection 19(i),49(2)*

Decision:

The Chief Safety Officer accepts the Applicants, the owner of the *Hebron Installation*, proposal to use wood products for certain applications according to Hebron procedures and fibre-reinforced grating on certain escape routes and non-escape walkways in lieu the requirements prescribed by the Petroleum Offshore Installation Regulations Subsection 19(i),49(2). The following conditions apply:

1. The inventory of wood volumes is kept as low as possible.
2. Fibre-reinforced grating is not installed in areas that have a risk of produced hydrocarbon fires.



Chief Safety Officer. *Acting*