

## <u>Chief Safety Officer Decision</u> (<u>Application for Substitution, Equivalency, or Exemption</u>)

Date:

20 April Zoi8

**C-NLOPB Reference:** 

2017-RQ-0122

Applicant:

**Suncor Energy** 

**Applicant Reference:** 

294

Installation Name:

Terra Nova FPSO

**Authority:** 

Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act,

subsection 146(1) and section 201.66

Regulation:

Subparagraph 25(6) of the Newfoundland Offshore

Petroleum Installations Regulations

## **Decision:**

The Chief Safety Officer accepts the Applicant's, the owner of the *Terra Nova FPSO*, use of Lloyd's Register approved actuated butterfly valves on deluge skids, in lieu of the *Newfoundland Offshore Petroleum Installations Regulations*, which specifies the use of *National Fire Protection Association 15, Standard for Water Spray Fixed Systems for Fire Protection*.

Chief Safety Officer