

Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date:

20 APRIL 2018

C-NLOPB Reference:

2018-RQ-0002

Applicant:

Husky Energy

Applicant Reference:

RQ-17-00000489

Installation Name:

West White Rose Platform

Authority:

*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Act, subsection 151(1) & section 205.069*


*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Newfoundland and Labrador Act, subsection
146(1) and section 201.66*

Regulation:

*Sections 8(8), 11(1) of the Newfoundland Offshore Petroleum
Installation Regulations*

Decision:

The Chief Safety Officer does not approve the proposal by the Applicant, the operator of the West White Rose Platform, to use Lloyd's Register as the Electrical Certification Organization as defined in the Canadian Electrical Code in lieu of Accreditation by the Standards Council of Canada.



Chief Safety Officer