



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date:

18 JUNE 2018

C-NLOPB Reference:

2018-RQ-0005

Applicant:

Husky Energy

Applicant Reference:

RQ-16-00000147

Installation Name:

West White Rose Platform

Authority:

*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Act, subsection 151(1) & section 205.069*

*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Newfoundland and Labrador Act, subsection
146(1) and section 201.66*

Regulation:

*Section 29(5) of the Newfoundland Offshore Petroleum
Installation Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the *West White Rose Platform*, to carry a minimum 10% reserve supply of each type of portable fire extinguisher in lieu of a spare charge for all portable fire extinguishers onboard provided used fire extinguishers are replaced and reserve supplies are replenished without delay.


Chief Safety Officer