



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 22 January 2019

C-NLOPB Reference: 2018-RQ-0051

Applicant: Husky Energy

Applicant Reference: RQ-16-00000154

Installation Name: West White Rose Project

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Section 28(1) of the Newfoundland Offshore Petroleum Installation Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the West White Rose Project, to install a NFPA 750 compliant water mist fire suppression system in the main power generator, emergency generator and firewater pump generator enclosure areas of the WWRP in lieu of the carbon dioxide, pressure water spray or high expansion foam systems referenced in the regulations.

This Decision is effective from the date of issuance herein until the earlier of:

- a) the date a Regulation referenced herein is repealed or the date a particular subsection that is the object of a substitution or exemption being granted hereby is amended or replaced, or
- b) the date on which the CSO and /or CCO (as applicable) revokes this Decision as a result of i) any enforcement action by the Board related to this Decision or ii) new information or analysis coming to light challenging the assessment upon which this Decision was based, including but not limited to any changes to commitments made by the Applicant in its application.

For greater certainty, Chief Safety Officer will no longer have authority under the Accord Acts to grant exemptions for Part III.1 transitional regulations once they are repealed.


Paul Alexander
Chief Safety Officer