



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 2022-Apr-21 | 11:23:57 AM NDT

C-NLOPB Reference: 2022-RQ-0008

Applicant: Seadrill Newfoundland Ltd.

Applicant Reference: WH-IR-011

Installation Name: West Hercules

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) & section 201.66

Regulation: *Section 25(4) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer approves the Applicant's, the owner of the *West Hercules*, use of deluge systems, with activation and alarm arrangements that are in compliance with *DNV Offshore Standards DNV-OS-D301 "Fire Protection"* and *DNV-OS-A101 "Safety Principles and Arrangements"* in lieu of the requirements in Subsection 25(4) of the *Newfoundland Offshore Petroleum Installations Regulations*.

DocuSigned by:

A handwritten signature in black ink, appearing to read "Paul Alcock".

94C2434A59B546B
Chief Safety Officer