



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 2024-Apr-10 | 11:23:52 AM NDT

C-NLOPB Reference: 2024-RQ-0017

Applicant: Stena Drilling Ltd.

Applicant Reference: DMX-RQ-24-011 Rev 1

Installation Name: MV-Stena DrillMAX

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Subsection 12(1)(a) and 12(7) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer approves the Applicant's, the owner of the Stena DrillMAX, proposal to use the installed redundancy of the power management system as required by the DNV class notation "DYNPOS-AUTRO", DNV Rules for Marine and Machinery Systems and Equipment, DNV Rules for Electrical Equipment and MODU Code Chapter 5 in lieu of the prescribed requirements surrounding emergency electrical power in the Newfoundland Offshore Petroleum Installations Regulations.

DocuSigned by:

A handwritten signature in black ink, appearing to be "Jm", written over a horizontal line.

Chief Safety Officer (Acting)