

Chief Safety Officer Decision (Regulatory Exemption)

Date: 4 August 2011

C-NLOPB Reference: 2011-RQ-0013

Applicant: Husky Energy

Applicant reference: WR 0166

Installation name: SeaRose FPSO

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: Subsection 49(2) of the Newfoundland Offshore Petroleum Installations Regulations

Decision:

The Chief Safety Officer authorizes the applicant, the Operator for the SeaRose FPSO, to use furniture, mattresses, drapes and flooring in the accommodations that are combustible but have fire retardant characteristics as outlined in RQF WR 0166.



Chief Safety Officer