



**Chief Safety Officer Decision (Regulatory Equivalence)**

**Date:** August 21, 2013

**C-NLOPB Reference:** 2012-RQ-0107

**Applicant:** ExxonMobil Canada Ltd., as managing partner of  
ExxonMobil Canada Properties

**Applicant Reference:** HEB-012

**Installation Name:** Hebron

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*  
  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Regulation:** *Section 28(1) of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Installation, to install a water mist system in the main power generator and gas compression turbine enclosures in lieu of carbon dioxide, pressure water spray or high expansion foam systems referenced in the regulations.

  
Chief Safety Officer