



Chief Safety Officer Decision (Regulatory Exemption)

Date: 12 Dec 2014

C-NLOPB Reference: 2014-RQ-0110

Applicant: Suncor Energy Inc.

Applicant Reference: RQF 266

Installation Name: Terra Nova FPSO

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Newfoundland Offshore Petroleum Installation Regulations, Subsection 9(4)*

Decision:

The Chief Safety Officer concurs with the Applicant's proposal to allow the swing arrangement of the emergency doors on the M03 Switchroom (AD-75007) and M05 Switchroom (AD-75016) to remain in its current configuration subject to the following conditions:

- The doors are used for emergency escape only and are clearly labelled as to their purpose
- The integrity of the gas tight seals are maintained at all times
- The differential pressure alarms and fire and gas detection protecting the spaces are operable at all times


Chief Safety Officer