



Chief Safety Officer Decision (Regulatory Equivalence)

Date: February 12, 2013

C-NLOPB Reference: 2012-RQ-0143

Applicant: Seadrill Canada Limited

Applicant Reference: WA-IR-015

Installation Name: West Aquarius

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsection 31(3) of the Newfoundland Offshore Installations Regulations*

Decision: The Chief Safety Officer authorizes the Applicant, the owner of the West Aquarius, to use *Det Norske Veritas' (DNV) Rules for the Classification of Offshore Drilling and Support Units, April 2004, and the 1989 Mobile Offshore Drilling Unit (MODU) Code with Amendments to 2001* for the fire detection systems in lieu of the *National Fire Protection Association (NFPA) 72E Standard* as referenced in the regulations.


Chief Safety Officer