



Chief Safety Officer Decision (Regulatory Equivalence)

Date: February 15, 2013

C-NLOPB Reference: 2012-RQ-0115

Applicant: Seadrill Canada Limited

Applicant Reference: WA-IR-012

Installation Name: West Aquarius

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsection 26(4) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision: The Chief Safety Officer accepts with the Applicant's, the owner of the West Aquarius, use of *Det Norkse Veritas'*(DNV) *EO Class Notation* for periodically unmanned machinery space in accordance with *DNV Rules for Classification of Ships Part 3 , Chapter 3* for the audible and visual alarms for the fire pump start up as these signals are relayed to the Central Control room (CCR) and other designated areas.


Chief Safety Officer