



Chief Safety Officer Decision (Regulatory Equivalence)

Date: 18 Feb 2015

C-NLOPB Reference: 2014-RQ-0121

Applicant: Seadrill Canada Limited

Applicant Reference: WM IR 040

Installation Name: West Mira

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Paragraph 27(11)(a) of the Newfoundland Offshore Installations Regulations*

Decision:

The Chief Safety Officer accepts that the accommodation sprinkler system on the West Mira was installed in accordance with *International Maritime Organization (IMO) Fire Safety Systems (FSS) Code Chapter 8* in lieu of Installation Regulations which prescribes the *National Fire Protection Association (NFPA) 13 Standard for the Installation of Sprinkler Systems*.


Chief Safety Officer