



Chief Safety Officer Decision (Denial of Request for Equivalency)

Date: February 29, 2012

C-NLOPB Reference: 2011-RQ-0023

Applicant: Suncor Energy Inc.

Applicant Reference: 180.1

Installation Name: Terra Nova FPSO

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Newfoundland Offshore Petroleum Installations Regulations, Section 32*

Decision:

The Chief Safety Officer *does not* approve the Application by the Applicant, the operator of the Terra Nova FPSO, to utilize the existing hydrocarbon gas detection system onboard the Terra Nova FPSO as a means of indirectly detecting the presence of hydrogen sulfide gas.


A/ Chief Safety Officer