



Chief Safety Officer Decision (Regulatory Equivalence)

Date: January 31, 2014

C-NLOPB Reference: 2013-RQ-0014

Applicant: Suncor Energy Inc

Applicant Reference: RQF 3.27

Installation Name: Terra Nova FPSO

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsection 35(2) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer concurs with the Applicant, the operator for the Terra Nova FPSO, to use the European pressure vessel design code (EN 13445-3) and European Pressure Equipment Directive (PED) 97/23/EC for the design and construction of the brazed plate evaporator for three new water chillers in lieu of the above requirements.



Chief Safety Officer