



Chief Safety Officer Decision (Regulatory Exemption)

Date: 03 July 2014

C-NLOPB Reference: 2013-RQ-0028

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-057

Installation Name: Hebron Installation

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Section 23(2)(a) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Installation, to provide a H-0 fire rated division for a portion of the cellar deck (Wellbay/Process areas) adjacent to the top of the GBS shaft instead of H-120.


Chief Safety Officer