



**Chief Safety Officer Decision (Regulatory Equivalence)**

**Date:** March 20, 2014

**C-NLOPB Reference:** 2013-RQ-0046

**Applicant:** ExxonMobil Canada Ltd., as managing partner of  
ExxonMobil Canada Properties

**Applicant Reference:** RQF-HEB-065

**Installation Name:** Hebron Installation

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*  
  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Regulation:** *Section 24 of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer accepts the use of fire hose reels within the Living Quarters of the Hebron Installation that will meet the requirements of the “*National Fire Protection Association, NFPA 14 Standard for the Installation of Standpipe and Hose systems*” in lieu of fire hydrants.

  
\_\_\_\_\_  
Chief Safety Officer