



Chief Safety Officer Decision (Regulatory Equivalence)

Date: March 25, 2014

C-NLOPB Reference: 2014-RQ-0011

Applicant: Helix Well Ops UK Ltd.

Applicant Reference: SKC-IR-014

Installation Name: Skandi Constructor

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Sub-section 29(9) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer accepts the Applicant's use of the *International Maritime Organization (IMO) Mobile Offshore Drilling Unit (MODU) Code 2001, Safety of Life at Sea (SOLAS) regulations and International Maritime Organization (IMO) Assembly Resolution A. 951(23)* for the inspection, maintenance and recharging of portable fire extinguishers onboard the Skandi Constructor in lieu of *National Fire Protection Association (NFPA) 10* as referenced in the regulations.



Chief Safety Officer