



Chief Safety Officer Decision (Regulatory Equivalence)

Date: May 28, 2014

C-NLOPB Reference: 2014-RQ-0014

Applicant: Helix Well Ops UK Ltd.

Applicant Reference: SKC-IR-OSH-003 Item 2

Installation Name: Skandi Constructor

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsections 8(8), 11(1), 11(2) of the Newfoundland Offshore Petroleum Installations Regulations and*
Section 8.14 of the Petroleum OSH Regulations

Decision:

The Chief Safety Officer accepts the Applicant's use of Det Norske Veritas' (DNV) Offshore Standards, DNV-OS-D201, Electrical Installation, January 2005 as well as compliance with the International Electrotechnical Commission (IEC) Publications for the design and installation of the electrical systems on the Skandi Constructor in lieu of the requirements in the regulations provided any new cabling is installed in accordance with the *Installation Regulations*.


Chief Safety Officer