



Chief Safety Officer Decision (Regulatory Equivalence)

Date: May 28, 2014

C-NLOPB Reference: 2013-RQ-0027

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-060

Installation Name: Hebron Installation

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsections 10(1) and 10(2) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer concurs with the Applicant, the operator of the Hebron Installation, to follow *NORSOK S-001, Technical Safety Standard* of a minimum of 12 air changes per hour for 95% of the time for naturally ventilated hazardous areas provided the areas ventilated are monitored by gas detectors that are operative at all times. The exception to this is the wellbay area which will be supplemented with mechanical ventilation.


Chief Safety Officer