

Chief Safety Officer Decision (Regulatory Equivalence)

Date: November 12, 2013

C-NLOPB Reference: 2012-RQ-0004

Applicant: Suncor Energy Inc.

Applicant Reference: RQF TNA 255

Installation Name: Terra Nova FPSO

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Sections 13(5) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator for the Terra Nova FPSO, to use automatic shutdowns in the circumstance of high exhaust temperatures for the key service generators in lieu of automatic fuel shut-off.



Chief Safety Officer