



Chief Safety Officer Decision (Regulatory Equivalence)

Date: October 15, 2013

C-NLOPB Reference: 2013-RQ-0020

Applicant: Husky Oil Operations Limited

Applicant Reference: RQF-WHP-0183

Installation Name: Husky Wellhead Platform

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Section 11(1) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the Husky Wellhead Platform, to use the Canadian Electrical Code (CEC) C22.1, Part 1 for the design, installation and maintenance of electrical equipment.

The authorization to use Canadian Electrical Code (CEC) C22.1, Part 1 should not be interpreted to mean that a particular mode of development (i.e. a gravity-based structure) has been accepted for use in the White Rose Extension Project. Such a determination is a Development Plan Amendment Approval


Chief Safety Officer