



Chief Safety Officer Decision (Regulatory Equivalence)

Date: September 17, 2012

C-NLOPB Reference: 2011-RQ-0036

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-020

Installation Name: Hebron Project

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Section 49(2) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Project, to use Chlorinated Polyvinyl Chloride (CPVC) piping and fittings for the sanitary drains systems in the accommodations provided:

1. The resistance to fire of the CPVC piping meets the criteria proposed in the RQF and:
2. The integrity of fire divisions are maintained at penetrations.



Chief Safety Officer