



Chief Safety Officer Decision (Regulatory Equivalence)

Date: 30 Sept 2014

C-NLOPB Reference: 2013-RQ-0010

Applicant: ExxonMobil Canada Ltd., as managing partner of ExxonMobil Canada Properties

Applicant Reference: HEB-042 Rev 1

Installation Name: Hebron

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *sub-sections 19 (i) and 49(2) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Installation, to use fiber reinforced plastic (FRP) grating for various mezzanines, walkway and access platforms in the Utility and Drilling areas, GBS, Drilling Equipment Set (DES) and Drilling Support Module (DSM) in lieu of materials having a fire durability equivalent to steel, provided:

1. Fiber reinforced plastic (FRP) grating is not used in primary and secondary escape routes;
2. Fiber reinforced plastic (FRP) grating has a Structural Fire Integrity Level 2;
3. Type approval certificates are reviewed and approved by the certifying authority as part of the verification process during detailed design and;
4. Fiber reinforced plastic (FRP) grating is checked after exposure to a fire prior to use.



Chief Safety Officer